

Hybrid Subcommittee Meeting #5



CALIFORNIA
TECHNICAL FORUM

**AYAD AL-SHAIKH
CHAU NGUYEN
CAMERON ASSADIAN**

High Level Overview


2

- Three measures to review:

- Process Boilers



- Pipe Insulation, Nonresidential



- Chillers, Non-Process



Hybrid Measure – Definition

3

- For a discrete (but growing) number of measures, document a framework for how to submit this *partially-deemed* measure
- Clarity that the submittal is expected to result in packets that:
 - Looks like a deemed measure to the customer
 - ✦ Known rebate based upon typical “normalizing unit” (ie, HP, kBTUH, etc)
 - ✦ No pre-approval required to install the measure
 - ✦ No requirement to document influence; uses a deemed Net-to-Gross value
 - ✦ Clarity on documentation that is required (up-front)
 - Provides deeper / more complete documentation than a deemed measure
- Improve customer participation in programs / customer perception
- Captures data in a structured format that could:
 - Improve inputs over time
 - Result in converting the hybrid measure to a deemed measure
- Balances:
 - Maximizing rate-payer funds by streamlining the process
 - Providing more site-level data than a typical deemed measure

Hybrid Measure – Target Measure

4

- Target Measure
 - Installed frequently, **repeatably** throughout the state
 - Enough clarity about the installation exists that there is acceptable trade-off between rigor and:
 - ✦ Reliability of the measure savings amount,
 - ✦ Persistence,
 - ✦ Double-dipping,
 - ✦ Gaming,
 - ✦ Etc.
 - Minimum and maximum project size or incentive amount could exist (per unit)
 - ✦ Ideally streamlined approach can reduce the minimum threshold of savings for accepting a project
 - ✦ Maximum project size may exist, but this is determined on a measure by measure basis

Hybrid Process Boiler Measure




CALIFORNIA
TECHNICAL FORUM

CHAU NGUYEN
AYAD AL-SHAIKH

Process Boiler - Histogram

6

- Deemed Measure: SWWH008 Process Boiler
 - Normal replacement of ≤ 20 MMBtu/hr process boiler



- Deemed: $\frac{3}{4}$ of the applications are $\frac{1}{3}$ of the savings
- Hybrid: $\frac{1}{4}$ of the applications are $\frac{2}{3}$ of the savings

Process Boiler – Savings Calculation

7

- Basic Calculation: $Savings = Rated\ Load * LF * opHr * \left(1 - \frac{Eff_{base}}{Eff_{meas}}\right)$
- Deemed: ≤ 10 MMBtu/hr
 - 1 – Sensitive variable
 - ✦ Norm Unit = Rated Load
 - 1 – Categorization
 - ✦ Boiler Type – Efficiencies
- Hybrid: $10 < x < 20$ MMBtu/hr
 - 3 – Sensitive variables
 - ✦ Norm Unit: Rated Load
 - ✦ Load Factor (calibrated)
 - ✦ Measure Case Efficiency
 - 1 – Categorization
 - ✦ Boiler Type – Base case efficiency


	HW I	HW II	Steam
Eff _{base}	.82	.82	.80
Eff _{meas}	.85	.90	.83

	HW I	Steam
Eff _{base}	.82	.80



Process Boiler – Hot Water

8

Deemed



Hybrid



Process Boiler - Data Collection

9

Input Variable	Value	Source
Rated Load	10 – 20 MMBtu/hr	Report with measure application/form
Load Factor	0.15 – 0.69	Link to SCG Load Balance Tool
# of gas equipment	1 - ∞	
LF for each equip	0.15 – 0.69	
opHr for each equip	1,000 – 8,760	
Annual gas bill		
opHr	8,760 hrs	Calibrated in LF
Eff _{base}	0.80 – Steam 0.82 – Hot Water	Set by boiler type
Eff _{meas}	0.83 – 0.97	<ul style="list-style-type: none"> - Provide spec sheet - FGA Record - Study/engineering data for the boiler model

Hybrid Pipe Insulation Measure




CALIFORNIA
TECHNICAL FORUM

CHAU NGUYEN
AYAD AL-SHAIKH

Pipe Insulation - Histogram

11

- Deemed Measure: SWWH017 Hot Water Pipe Insulation, NonRes
 - Installation of 1" insulation to bare hot water pipe





- Deemed: 83% of applications are 35% of the savings
- Hybrid: 17% of the applications are 65% of the savings
- Other Elements: degraded insulation, other liquid?

Pipe Insulation - Calculation

12

- Basic Calculations: $Savings = \frac{(Q_{base} - Q_{meas}) * opHr}{Boiler\ Eff} * length$
- Heat Loss $Q = f(\text{pipe/insulation conductivity, pipe diameter, insulation thickness, process temperature, ambient temperature, and wind speed})$
- NAIMA 3E Plus Pipe Insulation Software



Outdoor Pipe: $1" < x \leq 4"$



Pipe Insulation

13

- Deemed:
 - 1 – Sensitive variable (*Norm Unit* = length)
 - 3 – Categorizations
 - ✦ Location (Pipe location + CZ) – Wind speed
 - ✦ Boiler Type – Process Temp + Boiler Eff
 - ✦ Pipe Size – Average Pipe diameter
 - 1 – Additional documentation
 - ✦ Operating hours
- Hybrid:
 - 4 – Sensitive variables
 - ✦ Length
 - ✦ Pipe diameter
 - ✦ Operating hours
 - ✦ Process/Fluid Temperature
 - 1 Categorization
 - ✦ Pipe Location – Wind speed

Deemed	Windspeed
Indoor	0
Outdoor	Varied by CZ

Deemed	HW	Low Steam	Med Steam
Process Temp	136	242	294
Eff _{meas}	83.5%	80.7%	82.5%



Hybrid Chiller Measure



CALIFORNIA
TECHNICAL FORUM


CAMERON ASSADIAN
BRYAN BOYCE
AYAD AL-SHAIKH

Hybrid Chiller – Histogram

15

- Deemed Measures:


- SWHC020 Air Cooled Chiller and SWHC005 Water Cooled Chiller
 - ✦ Normal Replacement (NR) of Air-Cooled Screw Chiller (Const speed -> Const speed)
 - ✦ NR of Water-Cooled Centrifugal Chiller and Water-Cooled Screw Chiller (Var speed -> Var speed)



IOU claims data – 2019, Q1-Q4

Hybrid Chiller – Measure Breakdown

- Measure continuum



Use Subcategory	Gross Savings (kWh/yr)
Ventilation and Air Distribution	6,300,125
Space Heating and Cooling	11,475,674
Product chilling	6,273,811
Space Cooling	36,589,431
Retro-Commissioning Services	1,889,998
Air distribution (fan systems)	223,138
Pumping	969,291

Deemed

NR - Chiller Replacement, One-for-One

Hybrid

AR - Chiller Replacement, One-for-One

Custom

System Upgrade

- Questions

- ❑ Is this opportunity large enough (repeatable) to be considered Hybrid?
- ❑ Are the savings significant enough to encourage these stranded opportunities?

IOU claims data – 2019, Q1-Q4 Custom and Deemed

Hybrid Chiller – Measure Breakdown

17

- Basic Calculation: *DEER2020_Chiller_Workbook*
 - CPUC Calculator discussed later in the presentation (included in appendix)

- Deemed: MAT is Normal Replacement (NR)
 - One for One replacement
 - 2 – Categorizations
 - ✦ Efficiency Tier
 - ✦ Capacity

- Hybrid: MAT is Accelerated Replacement (AR)
 - One for One replacement
 - 3 – Sensitive Variables
 - ✦ Efficiency Tier
 - ✦ Capacity
 - ✦ Baseline Efficiency (Full Load and Part Load)
 - Tbd if we use just standard existing efficiency (or in-field EER)

Hybrid Chiller – Workbook Iterations

18

- Ran iterations for a variety of parameter combinations using the CPUC calculator
- Parameters included:
 - ❑ Program Administrator (PA): SCE
 - ❑ Climate Zone (CZ): 9
 - ❑ Measure Application Type (MAT): AR
 - ❑ Chiller Type: Water Cooled - Variable - Centrifugal
 - ❑ **Capacity (tons): 200, 700**
 - ❑ **kW/ton/IPLV: 0.571 / 0.360, 0.526 / 0.342**
 - ❑ Existing Chiller Manufacture Date:
Dependent on Vintage
 - ❑ **Building Type:** Office - Large, Health/Medical - Hospital, Education – University
 - ❑ **Vintage:** old, ex
 - ❑ Non-standard rating: No
 - ❑ Lead Chiller: No
 - ❑ Square Footage: Dependent on Building Type

Chiller Information			Building Information	
Capacity (tons)			Building Type	Vintage
	kW/ton	IPLV		
200	0.571	0.360	Large Office	old
200	0.571	0.360	Large Office	ex
700	0.526	0.342	Large Office	old
700	0.526	0.342	Large Office	ex
200	0.571	0.360	Health/Medical - Hospital	old
200	0.571	0.360	Health/Medical - Hospital	ex
700	0.526	0.342	Health/Medical - Hospital	old
700	0.526	0.342	Health/Medical - Hospital	ex
200	0.571	0.360	Education -University	old
200	0.571	0.360	Education -University	ex
700	0.526	0.342	Education -University	old
700	0.526	0.342	Education -University	ex

Hybrid Chiller – Workbook Iterations

- Results:

Chiller Information			Building Information		Above Code/Standard		Customer/Above Existing Savings		Percent Difference Above Existing (%)		READI		Percent Difference (%)	
Capacity (tons)	kW/ton	IPLV	Building Type	Vintage	kWh/ton	kW/ton	kWh/ton	kW/ton	kWh/ton	kW/ton	kWh/ton	kW/ton	kWh/ton	kW/ton
200	0.571	0.360	Large Office	old	36.57	0.0153	85.13	0.0356	133%	133%	36.30	0.0152	0.7%	0.5%
200	0.571	0.360	Large Office	ex	33.46	0.0114	77.90	0.0266	133%	133%	33.2	0.0114	0.8%	0.4%
700	0.526	0.342	Large Office	old	33.71	0.0141	110.84	0.0463	229%	229%	33.4	0.014	0.9%	0.6%
700	0.526	0.342	Large Office	ex	30.85	0.0105	101.43	0.0347	229%	229%	30.6	0.0105	0.8%	0.5%
200	0.571	0.360	Health/Medical - Hospital	old	28.67	0.0156	66.74	0.0364	133%	133%	28.4	0.0155	0.9%	0.9%
200	0.571	0.360	Health/Medical - Hospital	ex	21.47	0.0133	50.00	0.0310	133%	133%	21.3	0.0132	0.8%	0.9%
700	0.526	0.342	Health/Medical - Hospital	old	26.43	0.0144	86.90	0.0474	229%	229%	26.2	0.0143	0.9%	0.9%
700	0.526	0.342	Health/Medical - Hospital	ex	19.80	0.0123	65.10	0.0404	229%	229%	19.6	0.0122	1.0%	0.7%
200	0.571	0.360	Education -University	old	35.84	0.0323	83.44	0.0751	133%	133%	35.6	0.032	0.7%	0.9%
200	0.571	0.360	Education -University	ex	29.11	0.0304	67.77	0.0709	133%	133%	28.9	0.0302	0.7%	0.8%
700	0.526	0.342	Education -University	old	33.04	0.0298	108.64	0.0978	229%	229%	32.8	0.0295	0.7%	0.9%
700	0.526	0.342	Education -University	ex	26.83	0.0281	88.23	0.0923	229%	229%	26.6	0.0278	0.9%	1.0%

- Two changes:

- Constant Speed -> Variable Speed
- DEER existing efficiencies used:

Chiller Size (tons)	Vintage	Existing Chiller kW/ton	Existing Chiller IPLV
200	Old	0.926	N/A
200	Ex	0.634	0.596
700	Old	0.926	N/A
700	Ex	0.577	0.550

Percent Difference between "Above Code/Standard Practice Savings" and "Customer/Above Existing Savings"

Percent Difference between READI data and "Above Code/Standard Practice Savings"

Hybrid Chiller – Workbook Iterations

20

- **Conclusions:**

- Above Code/Standard Practice Savings were approximately equal to the READI data
 - ✦ This calculator is producing the same values that we use in our Deemed statewide measures
 - ✦ Note Deemed values come from READI
- Accelerated Replacement savings (lower existing efficiency / constant->variable speed) significantly improve savings

Chiller Information		Percent Difference Above Existing (%)	
kW/ton	IPLV	kWh/ton	kW/ton
0.571	0.360	133%	133%
0.526	0.342	229%	229%

Questions:

Can we get in-field EER measurements to improve more?

- ✦ Percent increase was independent of capacity, building type, or vintage

- **Next**

- Run other cases: Over-ride base case efficiency, Lead chiller, Constant speed base case, Extended hours
- Check TRC:
 - ✦ Savings increase, but AR will use a first baseline full measures cost (rather than incremental measure cost)

Next Steps

21

- Additional activities for existing measures
 - Understand TRC implications
- Are there other examples that we want to explore right away
 - Lighting
 - RCx
 - Ag Pump Overhauls
- Complete a Draft Guidance Document on the Hybrid measures
 - Allow for clearer review of the concept
- Next meeting – Planned for about 3 weeks

Chiller Calc Tool Back-up

22

CPUC Calculator – General Information

23

General Project Information:	
Program Administrator:	SDG
Climate Zone:	7
Measure Application Type:	Normal Replacement (NR)

- This is where the Program Administrator (PA), Climate Zone (CTZ) and Measure Application Type (MAT) are inputted
- PA is only used in the calculations if the building vintage “Existing” is selected
- Otherwise PA is only descriptive

CPUC Calculator – Chiller Information

- Chiller Type, Capacity, Full Load Efficiency and IPLV are specified in this section
- Non-standard rating conditions may be entered if the conditions are different from those used in the DEER simulations
- Standard rating conditions used in the DEER simulations:
 - Entering chilled water temperature: 54°F
 - Leaving chilled water temperature: 44°F
 - Entering condenser temperature: 85°F (water-cooled), 95°F (air-cooled)
- There is also an option to select the “lead chiller”
 - First chiller to operate
 - Highest full load operating hours
 - Only takes place in a central plant with multiple chillers

CPUC Calculator – Chiller Information

25

Chiller Information	
Measure	
Required	Chiller Type: Water Cooled - Constant - Centrifugal Capacity: 100 ton
	Lead Chiller? No
<u>Measure Chiller Rating Information:</u>	
Non-standard rating conditions?	No
<u>Measure Chiller Efficiency Information:</u>	
Full Load Efficiency:	0.521 kW/ton
IPLV:	0.495 kW/ton

Select "Yes" if chiller is the primary chiller operating more than all other chillers

Select "Yes" if chiller rated at non-standard conditions

Required

CPUC Calculator – Chiller Information

Measure	
Chiller Type:	Water Cooled - Constant - Centrifugal
Capacity:	120 ton
<i>Measure Chiller Rating Information:</i>	
Non-standard rating conditions?	Yes
Off-rated Entering Condenser Temp:	deg. F
Off-rated Leaving Condenser Temp:	deg. F
Off-rated Leaving Evaporator Temp:	deg. F
<i>Measure Chiller Efficiency Information:</i>	
Full Load Efficiency:	0.521 kW/ton
NPLV:	0.495 kW/ton

If "Non-standard rating conditions" is "Yes", enter rating conditions within the provided limits.

Non-standard rating conditions? Yes

<= Enter value between 60 and 90 deg. F
 <= Enter value between 60 and 90 deg. F
 <= Enter value between 36 and 60 deg. F

CPUC Calculator – Chiller Information


Chiller type and capacity should be identical to measure chiller

Code/Standard Practice	
Chiller Type:	Water Cooled - Constant - Centrifugal
Capacity:	120 ton
<i>Default Code/Standard Practice Chiller Efficiency Information:</i>	
Full Load Efficiency:	0.541 kW/ton
NPLV:	0.488 kW/ton
<i>User Input Code/Standard Practice Chiller Efficiency Information:</i>	
Full Load Efficiency:	kW/ton
NPLV:	kW/ton

Default efficiency values based on 2016 Title 24 requirements, adjusted for off-rated conditions

Supporting documentation required if user-input code/standard practice values are entered

CPUC Calculator – Chiller Information



CPUC Calculator – Building Information

30

Building(s) Information			Ref Runs
Building Type	Vintage	Square Footage	Measure/Code Lower Bound
Office - Large	Recent	340,000	WtrCldCentChlr-Conv-0.748
Lodging - Hotel	Existing	300,000	WtrCldCentChlr-Conv-0.748

CPUC Calculator – Building Information

31

- Up to 10 different building information can be entered including DEER building type, DEER vintage and floor area
- Savings results are generated by weighting results for each building type by the user entered floor area
- If a New vintage is included, this implies the MAT is “Capacity Expansion”
- “Extended Hours” building type is only utilized in custom programs
- Savings are calculated per ton of capacity